



KERALA AGRICULTURAL UNIVERSITY

College of Agriculture, Padannakkad P.O., Kasargod Dist.

Pin: 671314, Kerala, India.

Phone: Direct: 91 467 2282699, Office: 91 467 2280616 E-mail: coapad@kau.in

No: E2-6892/2022

Date: 21.10.2024

CORRIGENDUM

Tender notice for installation of portable modular cold room

Ref: No. E2-6892/22 dated 10/10/2024 of CoA, Padannakkad – Tender notice for installation of portable modular cold room

The following specifications are corrected as

IV. Specifications

a. Technical parameter –

- Size outer dimensions: 2 m height x 10 m length x 9 m width.
- Insulation panel thickness: not less than 120 mm
- Panel material: Stainless steel food grade
- The entire cold room should be portable, wheels with locking system

Corrected as

- Size outer dimensions: 9.8 feet height x 10 feet length x 9 feet width
- Insulation panel thickness: not less than 60 mm
- Panel material: Stainless steel food grade (inside), PCGI material (outside)
- The entire cold room should be portable, wheels with locking system – this point is deleted

The last date for receiving tender is extended to 29.10.2024

Sd/-

Dr. Mini P K

Dean i/c

//Approved for issue//


Section Officer